

Department of Civil & Environmental Engineering
Birla Institute of Technology, Mesra, Ranchi.

1. **Building Safety Certificate Issuing Authority***


Civil & Env. Engineering Department
BIT MESRA, RANCHI-835215
Jharkhand (India)

2. **Building Safety Certificate No.***


Ref.No. Civil & Env./Test/2021-22/02

3. **Building Certificate Dated:**

21/02/2022


Civil & Env. Engg. Department
Birla Institute of Technology
Mesra, Ranchi-835215
Jharkhand


Secretary
Dev Sangha National School
(A unit of Dev Sangha Seva Pratisthan)
Bompas Town, Dev Sangha, Neoghar
(Jharkhand) 814114



Principal
Dev Sangha National School
Deoghar-814114


Department of Civil & Environmental Engineering
Birla Institute of Technology, Mesra, Ranchi.

Project/ Site: 1. DEV SANGHA INSTITUTE OF PROFESSIONAL STUDIES & EDUCATIONAL RESEARCH, DEOGHAR.
2. DEV SANGHA NATIONAL SCHOOL, DEOGHAR
Test Description: Rebound Hammer Test
Date of Testing: 12/02/2022
Instrument Details: Matest C386N
Test Method Code: IS 13311:1992 (Part-2)

NDT Test Report

The NDT test was done also. It was observed that these buildings are Safe.

LOCATION/MARKS	Average Compressive Strength in N/mm ²
B. Ed & D. El. Ed. BUILDING	33.00
M.Ed. BUILDING	30.34
DEV SANGHA NATIONAL SCHOOL	29.56


Professor Birendra Kumar Singh
(Principal Investigator)
Department of Civil & Env. Engineering
BIT MESRA, RANCHI-835215

Civil & Env. Engg. Department
Birla Institute of Technology
Mesra, Ranchi-835215
Jharkhand


Secretary
Dev Sangha National School
(A unit of Dev Sangha Seva Pratisthan)
Bompas Town, Dev Sangha, Deoghar
(Jharkhand) 814114


Principal
Dev Sangha National School
Deoghar-814114

कार्यपालक अभियंता का कार्यालय
भवन निर्माण विभाग, भवन प्रमंडल, देवघर।

Email: eengbcdeogar-jhr@nic.in

पत्रांक...57.....

दिनांक...21-01-2022

प्रेषक:-

कार्यपालक अभियंता,
भवन प्रमंडल, देवघर।

सेवा में,

Principal
Devsangha Institute of professional
Studies & Educational Research (DIPSER)
Bypass Town, Deoghar.

विषय :- भवन सुरक्षा प्रमाण-पत्र के संबंध में।


प्रसंग :- आपका पत्रांक DIPSER/2021-22/2497 दिनांक 18.01.2022


महाशय,

उपर्युक्त विषयक प्रासंगिक पत्र के संदर्भ में कहना है कि महाविद्यालय भवन की सुरक्षा मानकों की जाँच हेतु बी० आई० टी० मेसरा रॉची अथवा बी० आई० टी० सिन्दरी, धनबाद सक्षम प्राधिकार है। भवन का सुरक्षा एवं गुणवत्ता संबंधी मानक की जाँच हेतु अधोहस्ताक्षरी के पास प्रयोगशाला संचालित नहीं है।


अतः अनुरोध है कि महाविद्यालय के सुरक्षा संबंधी प्रमाण-पत्र के लिए बी० आई० टी० सिन्दरी धनबाद अथवा बी० आई० टी० मेसरा रॉची से अनुरोध अपने स्तर से किया जा सकता है।

विश्वासभाजन


कार्यपालक अभियंता
भवन प्रमंडल, देवघर।
21/01/22



Principal
Dev Sangha National School
Deoghar-814114



Secretary
Dev Sangha National School
(A unit of Dev Sangha Seva Pratisthan)
Bompas Town, Dev Sangha, Deoghar
(Jharkhand) 814114